



Legend:

1. Worktop material to be selected by designer:
Option 1: 32 mm thick solid Iroko boards to specification
Option 2: Solid Core laminate to specification
2. 18 mm thick MDF panels, doors and shelves with decorative high pressure laminate.
3. 300 mm deep removable shelf.
4. 125 x 18 mm hardwood plinth with lacquer to specification.
5. Stainless steel recessed door handle reverse fixed through door. Self-closing hinges and high quality cylinder type locks.
6. Laboratory taps: 300 mm high twin brass bib tap with anti-corrosive plastic coating, serrated nozzle outlets. Cold water supply, colour coded to DIN EN 13792
7. Twin 90° gas outlet with lever control and serrated nozzle outlets with anti rotation pin. Brass body with anti corrosive plastic coating to DIN EN 13792
8. Laboratory sink:
Option 1: heavy duty fireclay size 250 x 250 mm deep
Option 2: cast epoxy resin.
Sink to have acid resistant waste.
Note: polypropylene sink not acceptable.
9. Polypropylene dilution recovery trap 2,3 litres volume, anti-siphon, emptied by unscrewing the base from the trap, with certified resistance to chemicals.
10. 50 x 18 mm MDF battens with decorative high pressure laminate.
11. Twin socket and data outlet.
12. 2 No. Flush twin socket outlet.
13. Cable outlet and cover in colour to match worktop
14. Adjustable steel shelf supports.

Minimum Standards for materials and finishes:

Core material for worktops, doors and carcasses:
Dry Fibre Board (MDF) to I.S. EN 622-5 Class E1 formaldehyde content tested to EN 120.
Moisture resistant board to I.S. EN 622-5-MDF-H, class E1 formaldehyde content tested to EN 120.

Core materials to be finished with plastic laminates to comply with I.S. EN 438, grade HGS/HGP (including vertical panels, shelves and doors).
Balancing laminate to be used in all cases.

Edges of all laminated panels (if not postformed) to be finished with solid colour laminate (2 mm thickness), PVC or hardwood edges to seal all edges.

Solid timber to comply with IS EN 942, Class J10.
FSC/PEFC chain of custody certification required for all timber and timber products, including MDF.

Metal frames:
Generally 60x30 mm mild steel frame with welded end caps and adjustable feet. Epoxy powder coated to selected RAL colour.

Ironmongery:
Stainless steel door handles, reversed fixed through doors. High quality stainless steel or nickel plated self-closing hinges (180°) and high quality cylinder style lock on masterkey system to suit the school's requirements.

Hardwood plinth size to be coordinated with skirting height in rooms.

Note:

Alternative materials and finishes of equal or higher specification and performance are permitted.
Drawings to be read in conjunction with specification.

TEACHER'S SCIENCE BENCH - STB SCALE: 1:10/1:20

DRG No: 027

DATE: SEPT '09

CHECKED BY: -

PREPARED BY: -

REVISIONS:

REMARKS:

